




POWER UPRATES AT NPP TEMELÍN VVER-1000 PARAMETERS AND PERSPECTIVES

VVER2016, Prague, October 2016

martin.bica@cez.cz

ČEZ NUCLEAR FLEET



Temelín

- *PWR, 2xVVER-1000 V320*
- *U1 startup: 2000*
- *Thermal Power: 3120 MWt (104% of original)*



Dukovany

- *PWR, 4xVVER-440 V213*
- *U1 startup: 1985*
- *Up-rated Thermal Power: 1444 MWt (105% of original)*



TEMELÍN REACTOR POWER UPRATE (104%, IMPLEMENTED 2013) – NUMBERS



- **Reactor rated thermal power: 3000 MWt => 3120 MWt**
- **Generator electric output: 1018 => 1062 MWe (*) = +88 MWe total (2 units)**
- **Project total costs: 16 mil. EUR (431.5 mil. CZK) (20÷40x lower inv. costs per installed MWe than new builds)**

(*) Reference heat balance diagram – without district heating, $T_{CW} = 18,5\text{ }^{\circ}\text{C}$




+88 MWe / 16 mil. EUR

**+ ca. 0.66 TWh/year (with considered LF of 85%),
pay back < 2 years**

2,2 mil. EUR: equipment modif's

13,8 mil. EUR: analytical part, tests



**Utilization of VVER-1000, V-320 reserves
=> minimum equipment modifications**

... we constructed cheapest new clean power source ...

TEMELÍN REACTOR POWER UPRATE – TIMELINE




- **2010÷12:** analytical part -
 - NRI Řež
 - JSC TVEL (fuel vendor)
 - OKB-GP (original designer)
 - equipment manufacturers
- **2012/13:** implementation of equipment modifications (during refuel. outages)
personnel training
- **22.4.2013:** regulatory body permission
- **18.8.2013:** unit 2 at 3120 MWt
- **22.9.2013:** unit 1 at 3120 MWt

TEMELÍN REACTOR POWER UPRATE – BASIC PRINCIPLES



PRESERVATION OF ...

- fuel system design
- technological safety system's characteristics / parameters (flow rates, volumes ...)
- SG secondary side pressure (i.e. T_{CL})
- power limits (abs. values) for operation with N-1 / N-2 loops in operation
- **safety analysis acceptance criteria**
- limits / acceptance criteria of other types of analysis / proofs (strenght, lifetime, EQ, ...)



TEMELÍN REACTOR POWER UPRATE – PROJECT SCOPE – ANALYTICAL PART, EQUIPMENT MODIFICATIONS



ANALYTICAL PART

- SAFETY ANALYSES
- Update of methodologies for reload design and reload safety evaluation
- Operational modes, update of OPERATIONAL PROCEDURES
- STRENGTH, LIFETIME, EQ evaluations
- EQUIPMENT PERFORMANCE at uprated power (design functions, limits)
- Chemistry, radiation monitoring
- Environmental impact

PERMITS

- SONS (nuclear regulatory body)
- Ministry of Industry

PERSONNEL TRAINING

- classroom, simulator

EQUIPMENT MODIFICATIONS

- Electric equipment (generator, output conduits)
- I&C
- Technological systems

STARTUP TESTS

96 → 98 → 100%

- Standard reactor physics tests, protection system calibrations
- Evaluation of parameters, Equipment diagnostics tests
- Test of 1 abnormal transient

TEMELÍN REACTOR POWER UPRATE – EQUIPMENT MODIFICATIONS



ELECTRIC EQUIPMENT



- Uprate of generator Sn (1111 MVA => 1250 MVA) ... new PQ diagram, modification of „zero conjunction“ (cooling)
- Modification of generator breaker cooling system
- Adjustment of protection settings, excitation system limiters, ASRU SW, etc. ...

I&C

- Modification of RTS and LS setpoints (N-flux based setpoints, DNB protections)
- Expansion of instrument span of several measuring channels (Fsteam, Fconden., Fhpr)
- Modifications of settings: main controllers, specific applications (NAPs, Beacon)

TECHNOLOGICAL SYSTEMS

- Increase of hydraulic head of condensate pumps




* % of total costs for equipment modifications

FURTHER UPRATE STEPS – INCREASE OF UNIT EFFICIENCY / EL. OUTPUT



New turbine low-pressure parts (2014/15)



**Increase of thermodynamic efficiency =
increase of MWe output
(> +22 MWe/unit (*))**

() Depending on external conditions*


**Reactor power uprate + new LP parts = +66 MWe/unit
1018 => 1084 MWe
real performance even better based on external conditions)**

Some reliability issues during first 2 years of operation of new LP parts ... their resolution is current priority to gain all the performance benefits

FURTHER UPRATE STEPS – INCREASE OF UNIT EFFICIENCY / EL. OUTPUT



Increase of energy conversion efficiency (unit power output) through optimization of secondary side design



Implementation planned for 2017÷18


ADDITIONAL POWER UPRATE AT TEMELÍN VVER-1000 – PERSPECTIVES, VIABILITY



Limits of additional „safe“ and „low-cost“ power uprate:

- New (uprated) operational state (parameters) remain covered (encountering uncertainties) by initial states of safety analyses and equipment analyses (strenght, lifetime, ...) ... „mini-uprate“ principle => *no need for repeated extensive analytical work*
- Equipment can operate on increased parameters w/o attacking its limits ... => *no need for extensive equipment modifications*

... met for +1% reactor power as a maximum for existing Temelín VVER-1000 design



ADDITIONAL POWER UPRATE AT TEMELÍN VVER-1000 – PERSPECTIVES, VIABILITY



UPCOMING YEARS ...

- **ČEZ will continue with modifications to increase energy conversion efficiency**
- **Additional reactor power uprate – not a current priority**
- **Outage lengths – currently negatively influenced by repeated inspections of weld-joints and other factors – are at present the factor with most dominant effect on operational results of ČEZ NPPs**

THE END



QUESTIONS ?

VVER2016, Prague, October 2016

POWER UPRATES AT NPP TEMELÍN VVER-1000 – PARAMETERS AND PERSPECTIVES